

**Product certificate number**

**No: 2613/0702/IEC62116/E6-CER**

**Manufacturer**

**Fronius International GmbH**  
Fronius Straße 5, A-4642 Sattledt, Austria



**Trademark**



**Model**

**Fronius SYMO 3.0-3-M / Fronius SYMO 3.7-3-M / Fronius SYMO 4.5-3-M /  
Fronius SYMO 5.0-3-M / Fronius SYMO 5.5-3-M / Fronius SYMO 6.0-3-M /  
Fronius SYMO 6.7-3-M / Fronius SYMO 7.0-3-M / Fronius SYMO 8.0-3-M /  
Fronius SYMO 8.2-3-M**

**Type of generating unit**

**Static Power Converter**

**Technical Data**

**Nominal Power**

**3 kW    3,7 kW    4,5 kW    5 kW    5,5 kW  
6 kW    6,7 kW    7 kW    8 kW    8,2 kW**

**Rated Voltage**

**230 V**

**Nominal Frequency**

**50 Hz**

**Firmware version**

**RECERBO: V0.3.23.0  
Power Stage: V1.2.11.1  
Filter: V0.9.24.1**

**Number of phases**

**Three phase**

**Isolation Transformer**

**No**

**Standard**

**IEC 62116:2014.** Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters.

The above-mentioned generating unit is certified according the SGS internal procedure PE.T-ECPE-18 based on the requirements of the UNE-EN ISO / IEC 17065.

This certificate cancels and supersedes certificate number 2613/0702/IEC62116/E5-CER.

This certificate is valid until: 4<sup>th</sup> of May of 2022. First issued on 13<sup>th</sup> of November of 2013.

**Madrid, 03<sup>rd</sup> of February 2020**

**Daniel Arranz Muñiz**  
Certification Manager

