

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELEKTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lísem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1180561

Product: Residual Current Circuit Breakers, RCCB

Type: Ex9L-N, Ex9L-H

Rating: 1P+N, 3P+N, $I_n=16, 25, 40, 63 A$, $I_{\Delta n}=10, 30, 100, 300, 500 mA$, type A and AC and delayed types S and G

Ordering firm: NOARK Electric Europe s.r.o.
Sezemická 2757/2, 193 00 Praha 9, Czech Republic

Manufacturer: NOARK Electric (Shanghai) Co., Ltd
Block V-7 A-1, Songjiang Industrial Zone,
Shanghai, China

Factories: Zhejiang Chint Electrics CO., Ltd.
No. 1 Chint Road, Chint Industrial Zone,
North Baixiang, Zueqing, Zhejiang Province, P.R. China

Trade mark:

The test results are stated in the test-report No.: 801529-01/01 of: 19.07.2018

A sample of the product was found to be in conformity with:
ČSN EN 61008-1 ed. 3:13+A1:15+A2:15+A11:16+A12:17, ČSN EN 61008-2-1:97+A11:99

Other data:


Certificate was issued on the basis of fulfillment of requirements of the "EZÚ certificate" certification scheme and on the basis of agreement No. 801529 between the client and the Electrotechnical Testing Institute.

Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 118/2016 Sb. (2014/35/EU) as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.

The validity of the certificate is limited to: 31.08.2021

15.08.2018

Prague


Mgr. Miroslav Sedláček
Head of Certification Body



801529-01

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 2180053

Ordering firm: NOARK Electric Europe s.r.o.
Sezemická 2757/2, 193 00 Praha 9, Czech Republic

Manufacturer/Licence holder: NOARK Electric (Shanghai) Co., Ltd
Block V-7 A-1, Songjiang Industrial Zone, Shanghai, China

Production site: Zhejiang Chint Electrics CO., Ltd.
No. 1 Chint Road, Chint Industrial Zone, North Baixiang, Zueqing, Zhejiang Province, P.R. China

Name of product: Residual Current Circuit Breakers, RCCB

Trade name:

Type of product: Ex9L-N, Ex9L-H

Rating: 1P+N, 3P+N, $I_n=16, 25, 40, 63$ A, $I_{\Delta n}=10, 30, 100, 300, 500$ mA, type A and AC and delayed types S and G

Electrotechnical Testing Institute on the basis of fulfillment the requirements of the „ESC Mark” certification scheme is granting a licence for using the following mark



This mark may be used for the product specified in this certificate within validity of the Agreement on the use of the ESC Mark by implementing all the rules stated in the Agreement.

The right to use the above mentioned mark for the product is based on:

- Test report No. 801529-01/01 of: 19.07.2018

A sample of the product was tested and found to be in conformity with:

ČSN EN 61008-1 ed. 3:13+A1:15+A2:15+A11:16+A12:17, ČSN EN 61008-2-1:97+A11:99

- inspection at manufacturing site according to Permanent Documents CIG 023 and CIG 024 No. 702863-01 of 22.08.2017
- the Agreement on the use of the ESC Mark No. 801529 concluded between the ordering firm and the Electrotechnical Testing Institute

Other data:

15.08.2018

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



* C E R / 2 1 8 0 0 5 3 *

801529-01