

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1170493

Product: Empty enclosure

Type: PHS, PNS, PXS, PNF, PXF, PNF-HW (see annex)

Rating: Ui 400 V AC (690 V AC a and 1000 V DC pro/for PHS) IP 40, IK - see annex

Ordering firm: NOARK Electric Europe s.r.o.
Sezemická 2757/2, 193 00 Praha 9, Czech Republic

Manufacturer: NOARK Electric Europe s.r.o.
Sezemická 2757/2, 193 00 Praha 9, Czech Republic

Factories: NOARK Electric Europe s.r.o.
Sezemická 2757/2, 193 00 Praha 9, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 702357-01/01 of: 29.06.2017

A sample of the product was found to be in conformity with:
ČSN EN 62208 ed. 2:12

Other data:


Certificate was issued on the basis of fulfillment of requirements of the "EZÚ certificate" certification scheme and on the basis of agreement No. 702357 between the client and the Electrotechnical Testing Institute.

Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 118/2016 Sb. (2014/35/EU) as amended and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.

The validity of the certificate is limited to: 31.07.2020

17.07.2017

Prague


Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



702357-01

Article Number	Type	No. of modules	Max static load	Door load	Degree of protection against external mechanical impacts	Maximum power loss of installed devices [W]
101492	PHS 4T	4	0,6kg	250g	IK08	10
101493	PHS 8T	8	1,1kg	250g	IK08	13
101494	PHS 12T	12	1,7kg	250g	IK08	16
101495	PHS 24T	24	3,3kg	250g	IK08	24
101496	PHS 36T	36	4,9kg	250g	IK08	26
101497	PNS 8T	8	1,1kg	250g	IK08	14
101498	PNS 12T	12	1,7kg	250g	IK08	22
101499	PNS 18T	18	2,5kg	250g	IK08	22
101500	PNS 24T	24	3,3kg	250g	IK08	24
101501	PNS 2x18T	36	4,9kg	250g	IK08	26
101502	PNS 36T	36	4,9kg	250g	IK08	26
101503	PNS 48T	48	6,5kg	250g	IK08	28
106196	PNS 3x18T	54	7,1kg	250g	IK08	28
101504	PNS 8W	8	1,1kg	250g	IK08	14
101505	PNS 12W	12	1,7kg	250g	IK08	22
101506	PNS 18W	18	2,5kg	250g	IK08	22
101507	PNS 24W	24	3,3kg	250g	IK08	24
101508	PNS 2x18W	36	4,9kg	250g	IK08	26
101509	PNS 36W	36	4,9kg	250g	IK08	26
101510	PNS 48W	48	6,5kg	250g	IK08	28
106197	PNS 3x18W	54	7,1kg	250g	IK08	28
101511	PNF 8T	8	1,1kg	250g	IK08	14
101512	PNF 12T	12	1,7kg	250g	IK08	22
101513	PNF 18T	18	2,5kg	250g	IK08	22
101514	PNF 24T	24	3,3kg	250g	IK08	24
101515	PNF 2x18T	36	4,9kg	250g	IK08	26
101516	PNF 36T	36	4,9kg	250g	IK08	26
106198	PNF 3x18T	54	7,1kg	250g	IK08	28
101517	PNF 8W	8	1,1kg	250g	IK08	14
101518	PNF 12W	12	1,7kg	250g	IK08	22
101519	PNF 18W	18	2,5kg	250g	IK08	22
101520	PNF 24W	24	3,3kg	250g	IK08	24
101521	PNF 2x18W	36	4,9kg	250g	IK08	26
101522	PNF 36W	36	4,9kg	250g	IK08	26
106199	PNF 3x18W	54	7,1kg	250g	IK08	28
101525	PXS 3	3	0,5kg	250g	IK07	10
101526	PXS 12	12	1,7kg	250g	IK07	22
101527	PXS 24	24	3,3kg	250g	IK07	24
101528	PXS 36	36	4,9kg	250g	IK07	26
101529	PXF 12T	12	1,7kg	250g	IK07	22
101530	PXF 24T	24	3,3kg	250g	IK07	24
101531	PXF 36T	36	4,9kg	250g	IK07	26
101532	PXF 12W	12	1,7kg	250g	IK07	22
101523	PXF 24W	24	3,3kg	250g	IK07	24
101524	PXF 36W	36	4,9kg	250g	IK07	26



Handwritten signature