

In Using



Warning

If the battery system needs to be moved or repaired, the power must be cut off and the

battery is completely shutdown;

2) It is prohibited to connect the battery with different type of battery.

3) It is prohibited to put the batteries working with faulty or incompatible inverter;

4) It is prohibited to disassemble the battery (QC tab removed or damaged);

5) In case of fire, only dry powder fire extinguisher can be used, liquid fire extinguishers

are prohibited;

6) Please do not open, repair or disassemble the battery except staffs from Pylontech or

authorized by Pylontech. We do not undertake any consequences or related

responsibility which because of violation of safety operation or violating of design,

production and equipment safety standards.